


6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.

- Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
- The staircase treads and flooring (grooving) to avoid falling of children.
- As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
- Periodical maintenance and care should be taken to maintain all fire protection equipments.
- Mock drill has to be conducted at regular intervals in consultation with the District Fire Officer, Fire and Rescue Services, South Chennai District at Ashok nagar, Chennai- 600 083
- The classrooms should always be in the ground floor upto 3rd standards.
- The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
- The classroom doors/ windows shall always open outwards.
- The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
- The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
- A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside.
- This door shall not have any arrangement for locking from outside.
- The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act

the License issued will stand cancelled.



Principality
STATION OFFICER
FIRE AND RESCUE SERVICE
TAMILNADU FIRE & RESCUE SERVICE STATION
NO. 18, MOSQUE COLONY MAIN ROAD,
RAJAKILPAKKAM, CHENNAI-600 073.

To:

THE PRINCIPAL,
AS-SADIQ NURESERY & PRIMARY SCHOOL,
NO.18, MOSQUE COLONY MAIN ROAD,
RAJAKILPAKKAM, CHENNAI-600 073.

CC : District Officer, South Chennai District

- 1A7 -

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE NO: 195V/TBM/2023
C.R.NO : 562 V/TBM/2023

Tambaram Fire and Rescue
Service Station.

DATE : 26.09.2023

Subject: Fire and rescue service department – Tambaram Fire and
Rescue Service Station for purpose of no objection
certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004
(2) G.O. No.123 School Edu (2) Dept, Date : 14.09.2004
(3) Date of Requisition letter from THE PRINCIPAL
AS-SADIQ NURSERY&PRIMARY SCHOOL

Date – 19.09.2023

Based on the Govt. order mentioned above and the requisition letter given by the AS-SADIQ NURSERY& PRIMARY SCHOOL at NO.18, MOSQUE COLONY MAIN ROAD, RAJAKILPAKKAM, CHENNAI-600 073. Tamil Nadu the building and premises comprises of Floors owned/ the AS-SADIQ NURSERY& PRIMARY SCHOOL Running in a GROUND+FIRST FLOOR ONLY have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 26.09.2023 in the presence of Principal and that the school is granted NOC for a period of one year from 26.09.2023 to 25.09.2024 subject to the conditions stated below.

THIS CERTIFICATE DOES NOT VALID BY SWIMMING POOL IN THAT PREMISES AREA
THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE SERVICES STATION ,G.TAMILPANDI ON 26 / 09 / 2023

CONDITIONS

1. This License is valid for **ONE YEAR** from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.

Tamparam City Municipal Corporation
SANITARY CERTIFICATE

Roc.No.2679/2022/H1

Dated: 21.09.2023


Certified that **AS-SADIQ NURSERY & PRIMARY SCHOOL, No. 18, Masjid Colony Main Road, Rajakilpakkam, Chennai - 600073**, has been inspected by the Sanitary Inspector and the Building and premises are found satisfactory on the following aspects.

1. The ventilation & Lighting Facilities are Satisfactory.
2. The building is maintained properly.
3. The room and surroundings are maintained neat and clean.
4. The sanitary arrangements provided are adequate and satisfactory.
5. The supply of drinking water is wholesome.

The Sanitary certificate may be issued subject to the following conditions:

- ❖ The garbage generated within the building premises should be collected and disposed of properly by appointing required sanitary staff.
- ❖ On no account the garbage should be burnt.
- ❖ Adequate fire safety precautions should be made.
- ❖ Safe and protected drinking water alone should be supplied to the children for consumption.
- ❖ The premises should be inspected periodically for mosquito breeding places and all control measures should be taken to keep the premises mosquito free.
- ❖ For running a food establishment / canteen, permission should be obtained from the food safety department.
- ❖ Incinerator shall be installed for safe disposal of sanitary napkins.
- ❖ The lab in charge should be well trained in handling the fire extinguisher.
- ❖ No smoking board should be displayed at predominant places with in the premises.
- ❖ No account sale of tobacco products should be permitted within the premises.
- ❖ Any occurrence of communicable disease should be notified to the Public Health Department.
- ❖ One time use and throw plastic is banned strictly by the Tamil Nadu Government. So ensure "Plastic Free" in your premises.
- ❖ Issued on 21.09.2023 Valid up to 20.09.2024 valid for One year only.
- ❖ This certificate issued is liable to be cancelled at any time on infringement of any of the above set conditions and for improper maintenance of sanitation, improper maintenance of the building as well as urinals and toilets in the buildings.




Sanitary Officer
Tamparam City Municipal Corporation



FORM - D

FORM OF LICENCE UNDER SUB-SECTION (1) OF SECTION 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT, 1965 (TAMIL NADU ACT 13 OF 1965) REFERRED TO IN RULE 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

Licence No. 24/2021

LICENCE

Public Building Licence is hereby granted to Thiru As Sadiq Nursery And Primary School/son of Thiru Mohideen 'M' now residing at 18, Masoothi colony main road rajakilpakkam RAJAKIZHPAKKAM Revenue Village, TAMBARAM Taluk, Chengalpattu District - 600073 of Tamil Nadu State for the purpose and in respect the building specified in the statement below and subject to the conditions and for the period mentioned under.

Date: 11-10-2023

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building (Door number, Street Number & Name of the Place)	Purpose for which the building is licensed to be used as public building	Number of persons to be accommodated
18 Masoothi colony main road rajakilpakkam RAJAKIZHPAKKAM, TAMBARAM, Chengalpattu, Tamil Nadu, 600073	Primary school/ Day care	170

Fee paid Rs. 1000.0 vide Challan No. 20230929013107, Dated: 30-09-2023

Period of validity of the licence shall be from the 11-10-2023 to the 10-10-2026 inclusive

Signature valid

Digitally signed by S. AVITHA
Date: 11/10/2023 08:29:03 IST

District : Chengalpattu

LICENCE ISSUING AUTHORITY

This certificate is digitally signed and does not require any seal / signature in original.



Genuineness of the certificate can be verified by:

(a) Keying in the unique certificate number 24/2021 in the URL <https://tncdistrict.tn.gov.in/tnceda/VerifyCert.html>.

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

Certificate validity period : 11-10-2023 to 10-10-2026

KDis.4993/2023/A1
Dated:10/01/2024

TALUK OFFICE
TAMBARAM

FORM D

Form of License under Sub Section (1) of section 6 of the Tamil Nadu Public Building (License) Act, 1965 (Tamil Nadu Act 13 of 1963) referred to in rule 6 of the Tamil Nadu Public Building (Licensing Rules 1966).

LICENSE NO: 24/2021

License Fee Rs.1000/-
remitted in SBI Bank,
Tambaram on : 04/01/2024


License is hereby granted to **ASSADHIQ NURSERY & PRIMARY SCHOOL, LOCATED AT NO.18, MASJID COLONY MAIN ROAD, RAJAKILPAKKAM VILLAGE, TAMBARAM TALUK, CHENGALPATTU DISTRICT, CHENNAI - 600073** for the purpose in the in respect of the building specified in the statement of below subject to the conditions and for the period mentioned.

1. The period of valid of the license shall be from **16/09/2023 to 10/10/2023 (inclusive)**.

2. The building shall be utilized only for the purpose as specified to column (2) below

3. The number of persons to be accommodated should not exceed the number specified in Column (3) below.

Location of the Building, Door No, and Name of the Place	Purpose of which the building to be used to a Public Building	Number of persons to be accommodated
NO.18, MASJID COLONY MAIN ROAD, RAJAKILPAKKAM VILLAGE, TAMBARAM TALUK, CHENGALPATTU DISTRICT, CHENNAI - 600073	Educational Purpose for Running School	170



Station: Tambaram
Date:10.01.2024

TAHSILDAR
TAMBARAM

10/01/24

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUBSECTION (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 (TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I certify that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. FOUNDATION:

- i) Depth below ground level : 5' 00" below G.L.
- ii) Nature of soil set out in the foundation. : Hard Soil.

The structural soundness of the building has been verified by me with reference to ISI loading standards 895 (latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.

A license may be granted for the period from **16.09.2023 to 15.09.2026**.

CERTIFIED that no Thatched buildings are used for conducting any classes for school premises .If any other Thatched buildings are constructed after the Issue of Certificate. ENGINEER is not held Responsible for any Fire Accident, that any incident occurs later and that aware that your LICENSE will be Cancelled. Periodical Repairs and Renovations shall be carried out to the above mentioned building. All Electrical points, wiring/ Gadgets has to be checked properly and to be maintained regularly. Periodic water proofing treatment is to be done as per standards.

All Electrical Panel Boards/ Main Switches / cables, Generator, Electrical Maintenance Room has to be kept in safety with lock & key position. Access to open terraces to be kept in lock & Key Position. The UG sump, manholes, OHT, Inspection Chamber, Septic Tank Openings as to be Sealed with cover slab. If any above mentioned Aspects were found violated at a later date after issue of this Report/ License we are not held responsible and this Report gets cancelled. Legal Aspects were not considered in this report.

Signature of the Correspondent

Signature of the Engineer.



R. MURUGESAN B.E., MIE., FIV, MICA,
CHARTERED ENGINEER,
PRIVATE PRACTISING ENGINEER, CLASS-I
GOVT. OF THE TAMILNADU
APPROVED BY THE DIST. COLLECTOR, KANCHEEPURAM
No. 11765/04 தாள்: 8/6/2004

FORM - B
STATEMENT OF ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS

Form of certificate of structural soundness under sub section (4) of section 4 of the Madras Public Buildings (Licensing) Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public Building (Licensing) rules 1977.

Certify that I have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian standard 875.

account the loading as per the latest Indian standard 875.				
Location of the building Door No. street name and name of the place	Age of the Building	Value of the Building	No. of Storeys	Short description of structure steel RCC framed or load bearing masonry.
1	2	3	4	5
AS-SADIQ NURSERY & PRIMARY SCHOOL, PO: 18, S.No 17/1A, 39/1, MOSQUE COLONY MAIN ROAD, CAJAKILPAKKAM, TAMBARAM - T.K., CHENGALPATTU - D.T., CHENNAI - 600 073.	G.F- 21 Yrs, F.F- 12 Yrs, G.F- 9 Yrs.	Rs.15.00/- Lacs	G.F, G.F+1 only	R.C.C Framed structure with plinth beams, Brickwork in Cement Mortar 1:6 Plastered with cm -1.5, wooden Doors and windows, white washing and colour washing. Flooring - Cement, Roofing-G.F+1 & G.F - R.C.C
Purpose for which the building is certified for use	The period for which the building will be structurally Sound	No. of persons to be accommodated	Remarks	
6	7	8	9	
For Running School	License may be given for the period of Three years from 16.09.2023 to 15.09.2026	About 170 Students	Building is Structurally Sound.	

Signature of the Correspondent



Signature of the Engineer.

R. MURUGESAN BE, MIE, FIV, MICA,
 CHARTERED ENGINEER,
 PRIVATE PRACTISING ENGINEER, CLASS-1
 GOVT. OF THE TAMILNADU
 APPROVED BY THE DIST COLLECTOR, KANCHEEPURAM
 No. ந.க.கம்-1/1766/04 தரம்: 8/6/2004

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOLS
STATEMENT ACCOMPANYING FORM 'A'

1. Door Number of the Building : AS-SADIQ NURSERY & PRIMARY SCHOOL,
 2. Location Street No. Ward No. : NO: 18, MOSQUE COLONY MAIN ROAD
RAJAKILPAKKAM, TAMBARAM - T.K.
 3. Name of place i.e. Corporation Municipality/ Panchayat/Panchayat Union/Township Cantonment : CHENGALPATTU - D.T., CHENNAI - 600 073.
TAMBARAM - T.K. CHENGALPATTU - D.T., CHENNAI - 600 073.
 4. Year of Construction : G.F - 2002 & F.F - 2011, G.F - 2014
 5. Approximate Cost of construction : About Rs. 15, 00,000/-
 6. Purpose for which the building is used : For Running School
 7. Purpose for which the building has hitherto been used. : -Do -
 8. Details of construction of the building (particulars) of the foundation, soil, specification of the various parts as under:-
 - a) Foundation : R.C.C Framed structure with plinth beams,
 - b) Basement : PCC 1:5:10, Brick work in Cement mortar 1:6
 - c) Superstructure : Brick work with cement mortar 1:6, plastered white washing .
 - d) Floor and roof : Flooring: Cement, Roofing G.F+1 & G.F - R.C.C
 9. Period for which license is required : Three years from 16.09.2023 to 15.09.2026
 10. Number of persons to be accommodated : About 170 students.
- Place : Chennai - 600 101.
Dated: 06.09.2023

Signature of the Correspondent

Signature of the Engineer
R. MURUGESAN B.E. MIE., FIV, MICA,
CHARTERED ENGINEER,
PRIVATE PRACTISING ENGINEER, CLASS-I
GOVT. OF THE TAMILNADU
APPROVED BY THE DIST. COLLECTOR, KANCHEEPURAM
No. 5, க.எம். V/11766/04 துண்: 8/6/2004



R. MURUGESAN, B.E., M.I.E., F.I.V., MICA
Chartered Civil Engineer, Govt. Regd. Valuer

S.P. ASSOCIATES

No. 3/13, Pancharathana Apartments, Welcome Colony, Thirumangalam,
Anna Nagar West Extension, Chennai - 600 101. Cell: 98410 62585

Issue Stability Certificate for Schools
Private Practising Engineer Class I
APPROVED BY : Dist. Collectors,
Kancheepuram & Thiruvallur Dist.

Ref.:

Date :

FORM - A

CERTIFICATE OF STRUCTURAL SOUNDNESS

I certify that I have inspected on AS-SADIQ NURSERY AND PRIMARY SCHOOL,
Buildings on 06.09.2023 that is located at SURVEY NO: 17/1A.39/1 NO: 18, MOSQUE
COLONY MAIN ROAD, RAJAKILPAKKAM, TAMBARAM - TALUK, CHENGALPATTU - DIST.
CHENNAI - 600 073. The following buildings were inspected by me,

- 1) MAIN BUILDING - GROUND FLOOR+1 ('L' SHAPE) - EAST & WEST FACING - R.C.C
ROOFING ONE BUILDING ONLY.
- 2) GROUND FLOOR - AUDITORIUM - NORTH FACING - R.C.C ROOFING ONE
BUILDING ONLY.

The certificate covers the above mentioned buildings only and does not include any other
structures or buildings. I found that there is no visible defect noticed in the buildings and it is
structurally sound to run the School.

This Certificate does not include any eventualities caused by Natural Calamities.
Periodical repairs and renovations will be carried out to the entire buildings then and there
whenever necessary.

This Certificate does not include any thatched sheds. If any Alteration/ Deviation
should not be carried out to any of the blocks without prior permission from the competent
authority. Further if any above mentioned aspects were found at a later date after issue of
this Certificate /License, the Engineer Not held Responsible any incident and this
certificate gets invalid.

This certificate is not conclude in respect of the property/building.

The owner is instructed to stop the classes during heavy gale, rain or wind as the
structure will withstand only normal velocity of wind, if not this certificate will automatically
be getting cancelled. Open terrace, Corridor and staircase must be barred.

This certificate has been issued only on physical inspection of the premises. No
approved plan for the building has been produced. As per Actual Construction of structures/
buildings plan has been produced for my perusal.

Place: Chennai - 600 101.

Date: 06.09.2023



Signature of the Engineer

R. MURUGESAN B.E., M.I.E., F.I.V., MICA,
CHARTERED ENGINEER,
PRIVATE PRACTISING ENGINEER, CLASS-I
GOVT. OF THE TAMILNADU
APPROVED BY THE DIST COLLECTOR, KANCHEEPURAM
No. ப.க.எம்-1/1766/04 நாள்: 8/6/2004

Resi. : 5/200, Mugappair West, Chennai - 600 037.